

Recommended Frequency of Inspections and Testing based on the IEE code of practice.

Type of Premises	Type of Equipment Note (1)	User Checks Note (2)	Class 1		Class 2	
			Formal Visual Inspection Note (3)	Combined Inspection And Testing Note (5)	Formal Visual Inspection Note (3)	Combined Inspection And Testing Note (5)
1	2	3	4	5	6	7
1 Construction Sites 110 V Equipment	S	None	1 Month	3 Months	1 Month	3 Months
	IT	None	1 Month	3 Months	1 Month	3 Months
	M	Weekly	1 Month	3 Months	1 Month	3 Months
	P	Weekly	1 Month	3 Months	1 Month	3 Months
	H	Weekly	1 Month	3 Months	1 Month	3 Months
2 Industrial Including Commercial Kitchens	S	Weekly	None	12 Months	None	12 Months
	IT	Weekly	None	12 Months	None	12 Months
	M	Before Use	1 Month	12 Months	3 Month	12 Months
	P	Before Use	1 Month	6 Months	3 Month	6 Months
3 Equipment Used by the Public	H	Before Use	1 Month	6 Months	3 Month	6 Months
	S	Note (6) +	Monthly	12 Months	3 Months	12 Months
	IT	Note (6) +	Monthly	12 Months	3 Months	12 Months
	M	Note (6) +	Weekly	6 Months	1 Month	12 Months
	P	Note (6) +	Weekly	6 Months	1 Month	12 Months
4 Schools	H	Note (6) +	Weekly	6 Months	1 Month	12 Months
	S	Weekly +	None	12 Months	12 Months	48 Months
	IT	Weekly +	None	12 Months	12 Months	48 Months
	M	Weekly +	4 Months	12 Months	4 Months	48 Months
	P	Weekly +	4 Months	12 Months	4 Months	48 Months
5 Hotels	H	Before Use	4 Months	12 Months	4 Months	48 Months
	S	None	24 Months	48 Months	24 Months	48 Months
	IT	None	24 Months	48 Months	24 Months	48 Months
	M	Weekly	12 Months	24 Months	24 Months	24 Months
	P	Weekly	12 Months	24 Months	24 Months	24 Months
6 Offices and Shops	H	Before Use	6 Months	12 Months	12 Months	24 Months
	S	None	24 Months	48 Months	24 Months	48 Months
	IT	None	24 Months	48 Months	24 Months	48 Months
	M	Weekly	12 Months	24 Months	12 Months	24 Months
	P	Weekly	12 Months	24 Months	12 Months	24 Months
	H	Before Use	6 Months	12 Months	12 Months	24 Months

Key			
(1)		(2)	User checks are not recorded unless a fault is found.
S	Stationary Equipment	(3)	The formal visual inspection may form part of combined inspection and tests when they coincide, and are recorded.
IT	Information Technology Equipment	(4)	If the class of equipment is not known it must be tested as a class 1 appliance.
M	Movable Equipment	(5)	The results of combined inspection and tests are recorded.
P	Portable Equipment	(6)	For some equipment such as children's rides.
H	Hand Held Equipment	(+)	By supervisor/teacher/member of staff